

2 carrier roofunits

€ 1.000,00	prijs per stuk / each		
€ -	totaalprijs / total amount	prijs / price	
code 1731-3		excl.	TRANSPORT / BTW / VAT/as is where is
Omschrijving/description	CAT A	ZH	

Wij hebben twee ongebruikte Carrier dakunits beschikbaar, specificaties op pagina 2.
14 KW koelvermogen, stekkerklaar, koelmiddel R22. Complete installatiemanual is beschikbaar

We have two Carrier roofunits unused available, specifications on page 2. cooling capacity is 14 KW,
coolant R22, installation manual is available.

Wir haben zwei ungebrauchte Carrier Heaters zur Verfügung, Technische Daten auf Seite 2.
Kühlkapazität 14 KW, Kühlmittel R22, komplette Unterlagen zur in Betriebsname stehen zur verfügung



Model 50SS-048---903AA



Postbus 17
 7480 AA Haaksbergen
 E-mail: ihb@ihbinternational.nl
 Web: www.ihbinternational.nl

Tel. + 31 (0)53 57 431 43
 Mob. + 31 (0)63 01 548 26
 Fax + 31 (0)84 87 266 72

BTW nr. 1014.51.556.B.02

Carrier Corporation TULSA, TEXAS		MODEL 50SS-048---903AA									
		SERIAL 2901G45276									
FACTORY CHARGED											
	QTY	VOLTS AC	PH	HZ	RLA	LRA	RCF	SYSTEM R-22	TEST PRESSURE GAGE		
COMP	1	400	3	50	10	64	6.3	LBS	2.8	kg	
COMP								LBS	kg	LO	
									300	PSI	
									2069	kPa	
									150	PSI	
									1034	kPa	
FAN MTR	QTY	VOLTS AC	PH	HZ	FLA						
OUTDOOR	1	400	1	50	2.0						
OUTDOOR											
INDOOR	1	400	1	50	4.0						
OTHER											
OTHER											
CHARGE SYSTEM PER INSTALLATION INSTRUCTIONS FOR OUTDOOR INSTALLATION								POWER SUPPLY	400	3 PH	50 HZ
								PERMISSIBLE VOLTAGE AT UNIT	440	MAX	360
DOWN SUPPLY	MIN CLEARANCE TO COMBUSTIBLE MATERIALS <u>1</u> INCHES <u>25</u> mm.										
	FOR FIRST <u>12</u> INCHES <u>305</u> mm. OF DUCT WHEN ELECTRIC HEATER IS INSTALLED										
SIDE SUPPLY	MIN CLEARANCE TO COMBUSTIBLE MATERIALS <u>0</u> INCHES <u>0</u> mm.										
	FOR FIRST <u>0</u> INCHES <u>0</u> mm. OF DUCT WHEN ELECTRIC HEATER IS INSTALLED										
*FOR INSTALLATION ON COMBUSTIBLE FLOORING OR CLASS A, B, OR C ROOFING MATERIAL											
ACCESSORY HEATER MODEL NUMBER	CHK. HERE	VOLTS	PH	HZ	HEATER FLA	MIN. CKT AMPS	FUSE OR CIRCBREAKER REQ. REC	MAXIMUM OVERCURRENT PROTECTION DEVICE	SINGLE PT. 30E MODEL NUMBER	HEATER UNIT DISCONNECT	
NONE		400	3	50	-	18.5	25	-	-	18	86
CPHEATER010A00		400	3	50	10	18.5	25	-	-	18	86
CPHEATER011A00		400	3	50	15.0	23.8	25	-	-	22	86
CPHEATER012A00		400	3	50	18	26.9	30	-	-	25	86
INSTALLER NOTE: 1. INSTALL ACCESS HEATER PER INSTALL INSTRUCTIONS ENCLOSED WITH HEATER. MAKE SPACE "CHECK HERE" FOR MODEL USED. USE MIN. CKT AMPS & MAX. OVER-CURRENT DEVICE AMPS LISTED FOR HEATER. IF NO HEATER IS USED, MAKE SPACE "CHECK HERE" FOR NONE. 2. HEATERS ARE MANUFACTURED BY ALLIED PRODUCTS DIVISION OR UNITED ELECTRIC.											
 50SS-048---903AA*											
 2901G45276											
 99NA904574-A											
 AVERTISSEMENT De Choc Électrique WARNING Electric Shock Hazard											